

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0809 - CPR - 1149

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Sewatek penetration seals

which consist of a penetration pipe made of NBR cellular rubber surrounded by PVC pipe, provided with (D-serie) or without pipe closure device, and may be equipped with ABS or metallic outer frame. Products are used as penetration seals in concrete wall and floor constructions and in massive-wood wall and roof/floor constructions made of cross laminated timber

produced by

Sewatek Oy
Sepäntie 4
FI-07230 Monninkylä

and produced in the manufacturing plant

Sewatek Oy
Sepäntie 4
FI-07230 Monninkylä.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA

ETA 12/0045

ETA 15/0411


under system 1 for the performances set out in this certificate are applied and that

the construction products fulfil all the prescribed requirements for these performances.

This certificate was first issued on August 24, 2015 and updated on December 28, 2015 and will remain valid as long as the ETA remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly, unless suspended or withdrawn by the product certification body.

Espoo December 28, 2015


Tiina Tirkkonen
Product Manager


Tatu Toivonen
Assessor

Product	Resistance to fire	
		Concrete wall or floor ETA 12/0045
Sewatek penetration seals - without pipe closure device - with pipe closure device (D-serie)	EI 30 – EI 120 ¹⁾	
Sewatek penetration seals D42, D62, D92, D105 and D140		EI 30 – EI 60 ²⁾

1) in end uses and with the provisions presented in the ETA 12/0045 Annex 1

2) in end uses and with the provisions presented in the ETA 15/0411 Annex 1